



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 25, 2009

Re: Meigs County
Rio Grande Community College
Storm Water Construction Activity
Notice of Violation
0GC00675*AG

Perry Varnadoe
Meigs County Community Improvement
238 West Main St.
Pomeroy, OH 45769

Dear Mr. Varnadoe:

On July 29, 2009, I visited your site on Chauncey Charles Drive in Pomeroy. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage

1. Part III.G.2.b.ii. of the permit states that operators shall stabilize channels and outfalls to prevent erosive flows. Techniques may include seeding, mulching, erosion control matting, sodding, rip rap, or rock check dams. **The outfalls from the site are causing erosion on the neighboring property (See attached photos). Please stabilize the channel immediately**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226.

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Sincerely,

A handwritten signature in black ink, appearing to read "M. See", with a long horizontal flourish extending to the right.

Michael See
Storm Water Section
Division of Surface Water

MS/mlm