



State of Ohio Environmental Protection Agency

**Southeast District Office**

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

**Re: Muskingum County  
Wellington Place  
Storm Water Construction Activity  
Notice of Violation  
0GC00667\*AG**

Mr. Andy Walther  
Stoneworks LLC  
2052 Cherry Valley Road  
Newark, Ohio 43055

Dear Mr. Walther:

On June 24, 2009 I visited your site on the intersection of Richvale and Northpointe Roads in Zanesville. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. **The area near the existing building pads must be stabilized with vegetation immediately.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226

Sincerely,

Michael See  
Storm Water Section  
Division of Surface Water

MS/dh