



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

December 13, 2012

RE: **NOTICE OF VIOLATION**
COLUMBIANA COUNTY
GUILFORD LAKE ESTATES
COMMUNITY WATER SYSTEM
PWS ID # OH1503412

Mr. Tim Falkenstein
P.O. Box 140
Rootstown, OH 44272

CERTIFIED MAIL

Dear Mr. Falkenstein:

This letter is notification that the Guilford Lake Estates public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Guilford Lake Estates PWS as reported on Monthly Operating Report (MOR) #5002 for October 2012. Results reported on the form indicated six (6) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer by January 11, 2013.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Kim Etters, Ohio EPA, NEDO, DDAGW
John D. Hull, Operator of Record