



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



December 14, 2012

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. Rebecca Hammer
7-Eleven, Inc.
1722 Routh Street, Suite 1000
Dallas, Texas 75205

Richland County
7-Eleven Store # 36177
Transient Non-Community PWS
PWS ID: OH7041912
STU ID: 7057776

Dear Ms. Hammer:

The Public Water System serving 7-Eleven Store # 36177 is in violation of the Ohio Administrative Code (OAC) for failing to comply with the operational requirements of OAC 3745-83-01 during the month of October, 2012.

In violation of OAC 3745-83-01(F)(2), the public water system failed to report both the free and combined chlorine residuals each day water was served. There were ten (10) days during the month in which no analysis was reported.

If you have any questions regarding this letter, please contact me at 419-373-3102 or via email at Kim.Burnham@epa.state.oh.us.

Sincerely,

Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

/llr

pc: Richland County Health Department
File: DDAGW – NWDO

