

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



December 14, 2012

John S Gordon
Thornville Duke And Duchess PWS
447 James Parkway
Heath, OH 43056

Licking County
Thornville Duke And Duchess PWS
Non-Community, Transient PWS
PWS ID: OH4536812
VIO ID: 6738801


Subject: Rescinding Violation – MOR

Your public water system was issued a notice of violation of Rule 3745-83-01 of the Ohio Administrative Code (OAC) on 5/3/2012 and on 7/30/2012 for the monitoring period of March 2012 and June 2012. Since the number of people served by this public water system on a daily basis is less than 1,000, the requirements to maintain the minim chlorine residual of 0.2 mg/L at all times and for submitting a monthly operating report by the 10th of the month are not applicable.

These violations have been rescinded.

If you have any questions, please contact me at (614) 728-3874.

Sincerely,


Raymond Shesky
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

c: Licking County Health Department
CDO/DDAGW
District File

RS/ct 4536812(rescindMD)March andJune2012