



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 18, 2010

Re: Muskingum County
Musk-Jim Granger Drive
Storm Water Construction Activity
Notice of Violation
0GC01158*AG

Mr. Jerry Nolder
Zanesville-Muskingum Co. Port Authority
205 N. Fifth Street
Zanesville, Ohio 43701

Dear Mr. Nolder:

On July 13, 2010, I visited your site on Jim Granger Drive in Zanesville. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Silt Fence


Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual.

Silt fencing at the site has degraded. Assess silt fencing throughout site and make repairs as necessary. Temporary storm water controls throughout the site must remain effective until the entire site has been stabilized.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5418 or Aaron Wolfe at (740) 380-5277.

Sincerely,

A handwritten signature in black ink, appearing to read "Chris Stephan", with a long horizontal flourish extending to the right.

Chris Stephan
Storm Water Section
Division of Surface Water

CCS/dh