



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korteski, Director

July 23, 2009

**Re: Muskingum County  
Zanesville South Elementary  
Storm Water Construction Activity  
Notice of Violation  
0GC01162\*AG**

Mr. Darrell Lear  
Zanesville City Schools  
160 N. 4th Street  
Zanesville, Ohio 43701

Dear Mr. Lear:

On June 24, 2009, I visited your site on 1063 Superior Street in Zanesville. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:


1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. **The soil pile at the upland area of the site needs to be stabilized.**
2. The unintended release or spill of a hazardous material must be minimized in accordance with the applicable SWP3 for the construction site according to Part I.B.5 of the permit. At no time may the storm water discharge contain amounts of hazardous substances equal to or in excess of the reportable quantity for that material set forth in 40 CFR 117. **One of the diesel fuel tanks was found to have a faulty valve on its secondary containment. This valve should be repaired or replaced in order to prevent possible spillage.**

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226.

Sincerely,

A handwritten signature in black ink, appearing to read 'M. See', with a stylized flourish at the end.

Michael See  
Storm Water Section  
Division of Surface Water

MS/dh

c: Paul Boster, Charter Hill Construction, Inc.