



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

September 17, 2010

Re: Noble County
Noble County Sanitary Sewers
Storm Water Construction
Notice of Violation
0GC01404*AG

Noble County Commissioners
Court House Room 210
Caldwell, Ohio 43724

Dear Commissioners:

On August 19, 2010, I visited your site on South Acres and various streets in Florance. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of stormwater associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following issues need addressed:

- 1. Part III.G.2.b. of the permit states:

Table 1: Permanent Stabilization

Area requiring permanent stabilization	Time frame to apply erosion controls
Any areas that will lie dormant for one year or more	Within seven days of the most recent disturbance
Any areas within 50 feet of a surface water of the State and at final grade	Within two days of reaching final grade
Any other areas at final grade	Within seven days of reaching final grade within that area

Table 2: Temporary Stabilization

Area requiring temporary stabilization	Time frame to apply erosion controls
Any disturbed areas within 50 feet of a surface water of the State and not at final grade	Within two days of the most recent disturbance if the area will remain idle for more than 21 days
For all construction activities, any disturbed areas that will be dormant for more than 21 days but less than one year, and not within 50 feet of a surface water of the State	Within seven days of the most recent disturbance within the area For residential subdivisions, disturbed areas must be stabilized at least seven days prior to transfer of permit coverage for the individual lot(s).
Disturbed areas that will be idle over winter	Prior to the onset of winter weather

Where vegetative stabilization techniques may cause structural instability or are otherwise unobtainable, alternative stabilization techniques must be employed.

At the time of my inspection the site was under construction. As a reminder I have included a stabilization chart. Please ensure the site is stabilized in accordance with the chart.

2. Part III.G.2.d.iii of the permit requires silt fence to be installed on a level contour. Silt fence should be utilized in accordance with the specification of the *Rainwater and Land Development* manual.

There appeared to be no silt fencing in place at the site. Apply silt fence to all downgrades and around unstabilized soil stock piles as needed.

3. Part III.G.2.g.ii. of the permit requires that off-site vehicle tracking of sediments be minimized. This is accomplished by constructing a proper construction entrance. The *Rainwater and Land Development* manual defines a construction entrance as a pad of aggregate 6 inches deep, 10 feet wide and 50 feet in length (30 feet for single residence lots).

A majority of complaints stem from poorly kept construction entrances causing sediment tracking onto roadways. As a reminder maintain all construction entrances and keep roads free of sediment.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5418 or Aaron Wolfe at (740) 380-5277.

Sincerely,



Chris Stephan
Storm Water Section
Division of Surface Water

CCS/dh