



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 28, 2009

Re: Perry County
Ebenezer Baptist Church
Storm Water Construction Activity
Notice of Violation
0GC01114*AG

Mr. Erwin Wolfe
Ebenezer Baptist Church
6682 State Route 312
Logan, Ohio 43138

Dear Mr. Wolfe:

On August 18, 2009, I visited your site on Township Road 234 outside of Maxville. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. **Please stabilize any bare areas on the backyard and on the hillside to the right of the building.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277.

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Sincerely,

A handwritten signature in black ink, appearing to read "Dustin Tschudy". The signature is written in a cursive style with a large initial "D" and a long, sweeping underline.

Dustin Tschudy
Storm Water Section
Division of Surface Water

DT/dh