OhioEPA
State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 30, 2009

Re: Ross County
Capital Crossing Senior Center
Storm Water Construction
Notice of Violation
0GC01218*AG

Bambi Baughn
Housing Services Alliance, Inc.
324 E. Court Street
Washington C.H., Ohio 45601

Dear Bambi Baughn:

On July 21, 2009, I visited your site on 341 Maple Street in Frankfort. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:

1. Part III.G.2.b.i (Table 1) of the permit requires that permanent stabilization be applied to areas at final grade within 7 days of the last disturbance. Permanent stabilization is defined as the establishment of permanent vegetative cover, decorative landscape mulching, matting, sod, rip rap and landscaping techniques to provide permanent erosion control. **Seed all areas behind the building and reseed any areas that did not take the first time.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5418.

Sincerely,

Joe May

Joe May
Storm Water Section
Division of Surface Water

JM/dh