



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director

August 10, 2010

Re: Scioto County
ODNR Watercraft Office
Storm Water General Permit
Notice of Violation
0GC01263*AG

Dean Palmer
ODNR Division of Engineering
2045 Morse Road, BLDG F-3
Columbus, OH 43229

Dear Mr. Palmer:

On June 30, 2010, Aaron Wolfe, Lynn Parkins, and I visited your site on Kenyon Road in Franklin Furnace. The purpose of the inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

1. Inlet Protection:

Part III.G.2.d.iv. of the permit states that sediment control practices must minimize the amount of sediment entering an active storm drain system, unless the system drains to a sediment settling pond.

Install more substantial inlet protection controls for both discharge points.

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact me at (740) 380-5418 or Aaron Wolfe at (740) 380-5277.

Sincerely,



Chris Stephan
Storm Water Section
Division of Surface Water

CCS/jg