



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 20, 2010

Re: Tuscarawas County
Rite Aid Store #2392
Storm Water Construction Activity
OGC01412*AG

Mr. Brad McLean
WXA Development, Inc.
7055 Engle Road #302
Middleburg Heights, Ohio 44130

Dear Mr. McLean:

On July 29, 2010, I visited the site located on W. High Street in New Philadelphia that had a construction stormwater permit with the Ohio EPA. The purpose of my inspection was to determine the compliance of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111.

At the time of my inspection, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

An NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.
2. All temporary sediment and erosion controls have been removed and properly disposed.
3. All sediment has been permanently stabilized to prevent further erosion.
4. Construction activity at the site has ceased.


It appears that your site meets the above criteria. If you agree, please submit an NOT within 45 days of the completion of construction activities. Failure to submit an NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency
Division of Surface Water
Storm Water Section
P.O. Box 1049
Columbus, Ohio 43216-1049

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5418.

Sincerely,



Chris Stephan
Storm Water Section
Division of Surface Water

CSS/dh

Enclosure: Notice of Termination