



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 14, 2009

Re: Tuscarawas County
Age of Steam Roundhouse
Stormwater Construction Activity
Notice of Violation
0GC01243*AG

Mr. John Dulac
dba Age of Steam
P.O. Box 427
Sugarcreek, Ohio 44681

Dear Mr. Dulac

On July 14, 2009, I visited your site off of County Road 71 in Sugarcreek. The purpose of the inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statutes, Ohio Revised Code (ORC) Chapter 6111. The following areas need to be addressed:

Permit Coverage:

1. Part III.G.2.b.i. (Table 2) of the permit requires that any area that will lie dormant for more than 21 days, but less than a year be stabilized within 7 days of the most recent disturbance. Temporary seeding may be accomplished any time between March 1 and November 1. Any seeding that occurs between November 1 and the spring seed will be considered dormant seeding. **The area around the sediment pond and the disturbed areas at the back of the site need vegetative stabilization (see attached photos for clarification).**
2. The unintended release or spill of a hazardous material must be minimized in accordance with the applicable SWP3 for the construction site according to Part I.B.5 of the permit. At no time may the storm water discharge contain amounts of hazardous substances equal to or in excess of the reportable quantity for that material set forth in 40 CFR 117. **The diesel container has two drain holes in the secondary containment vessel. Please plug these two drain holes immediately in order to prevent accidental spillage of fuel.**

Sediment and erosion controls for your site must meet the guidelines and design criteria set forth in the above mentioned *Rainwater and Land Development* manual. A copy of this manual may be obtained by contacting the Ohio Department of Natural Resources, Division of Soil and Water Conservation, at (614) 265-6610.

Within fourteen (14) days of receipt of this letter, please submit to me at this office a written notification as to actions taken or proposed to eliminate violations of the permit. Your response should include the dates, either actual or proposed, for the completion of the actions. If you have any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226.

Please be advised that failure to comply with the terms and conditions of your NPDES permit may be cause for enforcement action pursuant to the Ohio Revised Code Chapter 6111.

Sincerely,

A handwritten signature in black ink, appearing to read "Michael See", with a long horizontal flourish extending to the right.

Michael See
Storm Water Section
Division of Surface Water

MS/dh

Hole in Fuel
Container



