



State of Ohio Environmental Protection Agency

Southeast District Office

2195 Front Street
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 3, 2009

Re: Tuscarawas County
Midvale Elementary School
Stormwater Construction Activity
OGC00438*AG

Mr. Archie Gardner
P.O. Box 171
Gnadenhutten, Ohio 44629

Dear Mr. Gardner:

On July 6, 2009, I visited the Midvale Elementary School in Tuscarawas. The purpose of my inspection was to determine the compliance status of this site with the National Pollutant Discharge Elimination System (NPDES) permit for discharges of storm water associated with construction activity. The inspection was conducted under the provisions of Ohio's water pollution control statues, Ohio Revised Code (ORC) Chapter 6111.

At the time of my inspection, the site was inactive and it appeared that construction activities had been completed. In accordance with the NPDES permit, a Notice of Termination (NOT) must be submitted to the Ohio Environmental Protection Agency (Ohio EPA) to release you from the terms and conditions of this permit.

An NOT may be submitted to Ohio EPA if the following requirements have been fulfilled:

1. A perennial vegetative cover (or equivalent means of stabilization) has been established over 100% of the surface area disturbed during construction. The vegetative growth must be at a growth density of 70%.
2. All temporary sediment and erosion controls have been removed and properly disposed.
3. All sediment has been permanently stabilized to prevent further erosion.
4. Construction activity at the site has ceased.

It appears that your site meets the above criteria. If you agree, please submit an NOT within 45 days of the completion of construction activities. Failure to submit an NOT is a violation of the permit requirements and may affect your ability to obtain a NPDES permit in the future.

Please send the completed NOT to the following address:

Ohio Environmental Protection Agency
Division of Surface Water
Storm Water Section
P.O. Box 1049
Columbus, Ohio 43216-1049

If there are any questions, please contact Aaron Wolfe at (740) 380-5277 or me at (740) 380-5226.

Sincerely,



Michael See
Storm Water Section
Division of Surface Water

MS/dh

Enclosure: Notice of Termination