



Environmental Protection Agency


John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

OH4243312

Joy of Living Ministries

11/9/2011

FILE COPY



NOTICE OF VIOLATION – ACTION REQUIRED

November 9, 2011

Burt Hey
Joy Of Living Ministries Inc. PWS
18860 Dodd Road
P.O. Box 338
Brinkhaven, OH 43006

Knox County
Joy Of Living Ministries Inc. PWS
Non-Community, Transient PWS
PWS ID: OH4243312

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During November 2011 (Monthly)**

Joy Of Living Ministries Inc. PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful bacteria may be present.

ACTION REQUIRED:

1. **Investigate and eliminate the cause of bacterial contamination.** Special purpose samples may be collected to investigate the source of contamination or to verify elimination of the problem. (these samples cannot be collected to comply with monitoring or MCL requirements; label samples as "special purpose").
2. **Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
 - Mail or other direct delivery to each customer;
 - Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
 - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.
3. **Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - CDO. Include a copy of each notice distributed, published or posted.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049


614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov

Burt Hey
Joy of Living Ministries Inc. PWS
Page -2-

4. Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).

If you have any questions, contact this office at (614) 728-3791.

Sincerely,



Mark Boden
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Office

Enclosures: Tier 2 Public Notification
Public Notice Instructions and Verification Form

c: Knox County Health Department
Information Management Section, DDAGW/CO
District File Copy

MB/ct 4243312(Type22)(134219)