



Environmental  
Protection Agency


John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

FILE COPY

OH4243312

Joy of Living Ministries

11/14/2011



**NOTICE OF VIOLATION – ACTION REQUIRED**

November 14, 2011

Burt Hey  
Joy of Living Ministries Inc. PWS  
18860 Dodd Road  
P.O. Box 338  
Brinkhaven, OH 43006

Knox County  
Joy of Living Ministries Inc. PWS  
Non-Community, Transient PWS  
PWS ID: OH4243312

**Subject: Failure to Conduct Required Repeat Total Coliform Monitoring**

Joy of Living Ministries Inc PWS is in violation of monitoring requirements for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-21 for Fourth Quarter of 2011.

Ohio EPA records indicate that a total coliform-positive sample was collected from this water system on 10/7/2011 and the required repeat samples were not collected. To ensure the safety of drinking water provided by your system monitoring with all of the required repeat samples is essential.

**NO IMMEDIATE ACTION REQUIRED AT THIS TIME:**

However, in the future if your system receives a positive sample follow the steps below.

1. **Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the CDO at 614-728-3871.
2. **Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
  - Hand delivery to persons served by the water system;
  - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
  - Send to parents or guardians of children at schools or day care facilities;
  - Another delivery method approved in writing by the director;
  - Posted notices must remain in place for as long as the violation exists, but in no case for less than seven (7) days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

**NOTE:** Issuance of a Public Notice must be repeated every 30 days for as long as the violation exists, unless directed otherwise by the District Office. A verification form and a copy of the public notice, stating the corrective measures completed to date, must be submitted to the Ohio EPA.

Central District Office  
50 West Town Street, Suite 700  
P.O. Box 1049  
Columbus, OH 43216-1049

614 | 728 3778  
614 | 728 3898 (fax)  
www.epa.ohio.gov

Burt Hey  
Joy of Living Ministries Inc. PWS  
Page -2-

3. **Complete the enclosed verification form, within 10 days of issuing the Public Notice and mail it to Ohio EPA - CDO.** Include a copy of each notice distributed, published or posted.
4. **Collect a set of four (4) repeat samples, until one set is total coliform-negative to discontinue the Water Use Advisory.** Notify the people served by the water system when the water use advisory is discontinued.
5. **Monitor with at least five (5) routine samples in the month following a routine total coliform-positive result in accordance with OAC, Rule 3745-81-21(B)(7).**

If repeat samples were collected, submit them as soon as possible.

If you have any questions, contact this office at 614-728-3871.

Sincerely,



Mark Boden  
Environmental Specialist II  
Division of Drinking and Ground Waters  
Central District Office

Enclosures: Tier 1 Public Notification  
Public Notice Instructions and Verification Form

c: Knox County Health Department  
Information Management Section, DDAGW/CO  
District File Copy

MB/ct 4243312(Type26)4Q2011