



Environmental
Protection Agency

John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

FILE COPY



NOTICE OF VIOLATION – ACTION REQUIRED

CERTIFIED MAIL # 91 7108 2133 3932 1838 4448

November 3, 2011

Burt Hey
Joy Of Living Ministries Inc. PWS
18860 Dodd Road
Brinkhaven, OH 43006

Knox County
Joy Of Living Ministries Inc. PWS
Non-Community, Transient PWS
PWS ID: OH4243312

**Subject: Violation of Total Coliform Maximum Contaminant Level (MCL)
During Fourth Quarter of 2011 (ACUTE)**

Joy Of Living Ministries Inc PWS is in violation of the Maximum Contaminant Level (MCL) for Total Coliform established by Ohio Administrative Code (OAC), Rule 3745-81-14. Water samples have confirmed the presence of *E. colifecal* coliform in the drinking water. *Fecal coliform and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.* This is an Acute MCL violation requiring immediate action.

IMMEDIATE ACTION REQUIRED:

- 1. Consult with Ohio EPA within 24 hours** regarding public notice requirements. If you have not already received direction regarding this violation, contact the CDO at 614-728-3871.
- 2. Issue the enclosed public notice within 24 hours** in accordance with OAC, Rule 3745-81-32 using one or more of the following methods to reach all persons served.
 - Hand delivery to persons served by the water system
 - Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas
 - Send to parents or guardians of children at schools or day care facilities
 - Another delivery method approved in writing by the director
 - Posted notices must remain in place for as long as the violation exists.
 - Posted notices must remain in place for as long as the violation exists, but in **no case** for less than seven (7) days (even if the violation is resolved). The language in *italics* on the enclosed public notice is mandatory and must be included, as written. **Do not** make changes to the public notice without consulting with Ohio EPA beforehand.

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov