



State of Ohio Environmental Protection Agency

STREET ADDRESS:

Central District Office

MAILING ADDRESS:

Lazarus Government Center
50 W. Town St., Suite 700
Columbus, Ohio 43215TELE: (614) 728-3776 FAX: (614) 728-3898
www.epa.state.oh.usP.O. Box 1049
Columbus, OH 43216-1049

November 1, 2007

**Re: Madison County
Green Meadows Mobile Home Park
Community Water System
PWS ID No.:4901812**Michelle Davis
Park Manager
Green Meadows MHP
1 Thorn Locust Lane
London, OH 43140

Dear Ms. Davis:

This letter is to inform you of deficiencies on the monthly operating report submitted to our office for the Green Meadows Mobile Home Park. **Ohio Administrative Code (OAC) 3745-83-01 requires you to maintain (daily) a free chlorine residual of 0.2 mg/L or a combined chlorine residual of 1.0 mg/L in the distribution system at all times.** There were three (3) days in the month of September 2007, where minimum required chlorine residuals were not maintained and the Green Meadows Park MHP was in violation of OAC 3745-83-01.

Please take whatever means necessary to correct the problem of low chlorine residuals within the distribution system. If you have any questions, please call me at (614) 728-3870.

Sincerely,

Bridgette Marchio
Environmental Specialist II
Division of Drinking and Ground Waters
Central District Officec: Madison County Health Department
Winelco, Inc.
CDO File

BM/ct GreenmeadowsOctober 29

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korteski, Director