



OH1600811 ECHOING HILLS VILLAGE

38 06/01/09

2195 Front Street  
Logan, Ohio 43138



Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 29, 2009

Re: **COSHOCTON COUNTY  
ECHOING HILLS VILLAGE  
COMMUNITY  
OH1600811**

Mr. Buddy Busch, CEO  
Echoing Hills Village Inc.  
36272 County Road 79  
Warsaw, OH 43844

### **Notice of Violation - Failure to Monitor and or Record Filter Turbidity Results**

Dear Mr. Busch:

On April 17, 2009, the Echoing Hills Village water system failed to record the combined filter turbidity results in violation of rule 3745-81-74(D)(2) of the Ohio Administrative Code.

#### **Actions required as a result of the above violation**

**Action required:** **Notify the people served by the water system** using one or more of the methods and the timing as required by OAC 3745-81-32 to reach all persons served. The appropriate methods for your system are listed below.

**Timing:** As soon as practical, but no later than one year after learning of the violation.

**Methods:**

- Mail or other direct delivery to each customer; or
- Annual Consumer Confidence Report provided it's distributed within one year after learning of the violation; and
- If necessary to reach all persons regularly served, use other notification methods such as newspaper publication, public posting.


Posted notices must remain in place as long as the violation or situation exists, but in no case less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included as written. Do not make changes to the public notice without consulting with the Ohio EPA beforehand.

**Echoing Hills Village**  
**May 29, 2009**  
**Page 2**

**Complete the verification form within ten (10) days** of issuing the public notice and mail it to the Ohio EPA - Southeast District Office. Include a copy of each notice distributed, published, or posted.

If you have any questions, please contact me at (740) 380-5267.

Sincerely,



Robert B. Little  
District Representative  
Division of Drinking and Ground Waters

RBL/jg

Enclosures

- cc: Coshocton County Health Department
- cc: Toni Buchanan C.O. DDAGW
- cc: Jamie Wilkins, SEDO, DDAGW
- cc: Mike Morrow/Tom Mills, Echoing Hills Village

# DRINKING WATER NOTICE

## Monitoring requirements not met for the ECHOING HILLS VILLAGE

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During April 17, 2009, we did not complete all monitoring or testing for turbidity (cloudiness) from the filters as required and therefore cannot be sure of the quality of your drinking water during that time.*

### What Should I Do?

There is nothing you need to do at this time. You do not need to boil your water or take other corrective action.

This notice is to inform you that the ECHOING HILLS VILLAGE did not monitor and report results for the presence of turbidity in the public drinking water system during the April 17, 2009 time period, as required by the Ohio Environmental Protection Agency.

### What is being done?

Upon being notified of this violation, the water supplier will have taken steps to ensure that adequate monitoring will be performed in the future.

For more information, please contact \_\_\_\_\_ at \_\_\_\_\_ or \_\_\_\_\_  
name of contact                      phone number                      mailing address

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID# OH1600811

Date Distributed:

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR  
COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 3 VIOLATIONS**

The owner or operator of a community public water system with a Tier 3 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than one year** after the system learns of the violation, At a minimum, community public water systems must issue the notice **by mail or other direct delivery**. Public notice issued by other methods other than posting shall be repeated annually as long as the violation or situation persists.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p><b>Use one or more of the following methods to reach all persons served by the public water system:</b></p> <p>1. Public notice issued by mail or other direct delivery to each customer and service connection (where known) to which water is delivered by the public water system. The consumer confidence report delivered to customers by July 1 of each year may be used as long as the public notice includes all the required content and is delivered within the request time frame.</p>	<p><b>Describe actual methods used to notify public of the violation:</b></p> <p>1. Date of mailing/delivery</p>
<p><b>If the above methods do not reach all persons served,</b> also use any other method reasonably calculated to reach other persons regularly served by the public water system (e.g. publication in a local newspaper or newsletter, use of e-mail to notify employees, or delivery of multiple copies to central locations). If the notice is posted, it shall remain in place as long as the violation exists, but in no case less than 7 days.</p>	<p>A. Method(s)</p> <p>B. Date(s)</p>

**Please check if the public notice used was provided by Ohio EPA (other side of this form) or another acceptable notice was used:**

- A public notice as shown on the other side of this sheet was issued without changes.
- A different public notice was issued. **INCLUDE A COPY OF THE PUBLIC NOTICE.**

Signature of Responsible Official      Date

Printed Name and Title of Responsible Official

ECHOING HILLS VILLAGE  
NAME OF PUBLIC WATER SYSTEM

PWSID NUMBER: OH1600811  
COUNTY NAME: COSHOCTON

<p><b>For OEPA use only</b></p> <p>Date PN Received:</p> <p>PN acceptable:              PN not acceptable:</p>	<p>VIOLATION TYPE: <u>38</u></p> <p>MONITORING PERIOD <u>April 2009</u></p>
--	---