

\* O H 1 6 0 0 8 1 1 9 6 6 3 3 1 3 \*  
TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

16 AM: 39

2195 Front Street  
Logan, Ohio 43138Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 10, 2010

**RE: COSHOCTON COUNTY  
ECHOING HILLS VILLAGE WATER SYSTEM  
PWS ID: OH1600811**Mr. Buddy Busch, President/CEO  
Echoing Hills Village  
36272 CR 79  
Warsaw, Ohio 43844

Dear Mr. Busch:

Echoing Hills Village is in violation of OAC 3745-81-74 when the following monitoring requirements were not met during the month of July 2010:

The public water system failed to monitor for turbidity either continuously or every four hours that the water treatment plant was in operation on July 1 through 6, 2010.

**ACTION REQUIRED:**

Echoing Hills Village is required by OAC 3745-81-32(A)(2) to notify persons served by its water system of its failure to perform the monitoring that is established by OAC chapter 3745-81 or fails to comply with a testing procedure required by this chapter.

**Notify the people served by this water system.** Within 30 days issue the enclosed public notice in accordance with OAC, Rule 3745-81-32 by the following method(s) to reach all persons served.

- Posting in conspicuous locations, such as bulletin boards, restrooms, drinking fountains, vending areas;
- Mail or other direct delivery to each customer;
- Send to parents or guardians of children at schools or day care facilities E-mail, newsletters or newspaper;
- Posted notices must remain in place for as long as the violation exists, but in no case for less than seven days (even if the violation is resolved). The language in italics on the enclosed public notice is mandatory and must be included, as written. Do not make changes to the public notice without consulting with Ohio EPA beforehand.

**Complete the enclosed verification form within 10 days of issuing the Public Notice** and mail it to Ohio EPA - SEDO. Include a copy of each notice distributed, published or posted.

Echoing Hills Village Water System  
September 10, 2010  
Page 2

If public notification has not yet been issued for the violation, the public water system may use the enclosed example public notice to notify persons served by its water system. The public water system must send a copy of the actual public notice used and the verification form to this district office within ten days after it has issued the notice.

If you have questions, please call me at (740) 380-5267.

Sincerely,



Robert B. Little  
District Representative  
Division of Drinking And Ground Waters

RBL/cb

enclosure(s) Tier 2 Public Notification  
Public Notice Instructions and Verification Form

pc: Coshocton County Health Department  
IMS/DDAGW, CO  
Jamie Wilkins, DDAGW, SEDO

**PUBLIC NOTICE INSTRUCTIONS AND VERIFICATION FORM FOR  
NON COMMUNITY PUBLIC WATER SYSTEMS WITH TIER 2 VIOLATIONS**


The owner or operator of a community public water system with a Tier 2 violation or situation shall notify the persons served by the public water system as soon as practical but **no later than 30 days** after the system learns of the violation.

I HEREBY CERTIFY THAT THE PUBLIC WAS NOTIFIED BY THE FOLLOWING METHOD(S) INDICATED BELOW, AS DESCRIBED IN THE OHIO ADMINISTRATIVE CODE RULE 3745-81-32:

Required Method of Public Notification	Actual Method of Public Notification
<p><b>Use one or more of the following methods to reach all persons served by the public water system:</b></p> <ol style="list-style-type: none"> <li>Public notice issued by posting in conspicuous locations throughout the distribution system (required to remain posted for as long as the violation exists, but in no case less than 7 days)</li> <li>Public notice issued by mail or other direct delivery to each customer and service connection (where known).</li> </ol>	<p><b>Describe actual methods used to notify public of the violation:</b></p> <p>1A. Dates of posting <u>9/13/2010</u></p> <p>1B. Locations of posting <u>MAIL BOXES, COPY DISTRIBUTED TO ALL EMPLOYEES &amp; CLIENTS, A COPY DISPLAYED IN CONSPICUOUSLY IN ALL MAIN BUILDINGS ON CAMPUS.</u></p> <p>2. Date of mailing/delivery <u>9/14/2010</u></p>
<p><b>Schools and Day-Care Facilities</b> must notify parents or guardians of children being served by methods besides posting, such as a newsletter, e-mail notice, or direct mailing</p>	<p>A. Method(s) _____</p> <p>B. Date(s) _____</p>
<p><b>If the above methods do not reach all persons served</b>, also use any other method reasonably calculated to reach other persons served by the system (e.g. newsletter, use of e-mail to notify employees or students, or delivery of multiple copies to central locations).</p>	<p>A. Method(s) _____</p> <p>B. Date(s) _____</p>

**Please indicate below what public notice was used. INCLUDE A COPY OF THE PUBLIC NOTICE.**

- A public notice as provided was issued without changes.
- A different public notice was issued.

  
 \_\_\_\_\_  
 Signature of Responsible Person      Date 9/14/10

MICHAEL MORROW, COMPLIANCE OFFICER  
 Printed Name and Title of Responsible Person

Echoing Hills Village  
 OH1600811  
 Coshocton County  
 July 2010  
 Turbidity reporting (Vio. Type 38)

For Ohio EPA use only:	
Date PN received:	<u>9-16-10</u>
PN acceptable:	<input checked="" type="checkbox"/> <u>X</u> PN not acceptable:

### DRINKING WATER NOTICE

#### Turbidity monitoring not properly completed at Echoing Hills Village ~~216-392-3939~~

We routinely monitor turbidity of Echoing Hills Village drinking water. When we cannot monitor with a continuous analyzer, we are required to manually sample and analyze filtered water every 4 hours. During July 1 through July 6, 2010, our continuous turbidimeter was off line for required servicing. We did not collect and analyze finished water turbidity every 4 hours as required when manually conducting turbidity collection and analysis.

#### What should I do?

- *You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor. People with severely compromised immune systems, infants, and some elderly people may be at increased risk. These people should seek advice about drinking water from their health care providers.*
- *While turbidity in itself is not harmful, the presence of turbidity above certain levels can be indicative of the possible presence of other contaminants. While the level of turbidity of the finished water during July 1 through 6, 2010 was within the acceptable range, the frequency that we monitored the turbidity was not at the required minimum time interval required.*

#### What is being done?

Further testing shows that the turbidity levels continue to be in the acceptable range, the continuous turbidimeter has been repaired and placed into service and this problem has been resolved.

For more information, please contact Mike Morrow at 740-502-1131  
name of contact phone number

or at 36272 CR 79, WARREN, OH 43844  
mailing address

General guidelines on ways to lessen the risk of infection by microbes are available from the EPA Safe Drinking Water Hotline at 1(800) 426-4791.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

PWSID# OH1635012	Date Distributed: 9/13/10
------------------	---------------------------

Tier 2: Resolved Turbidity Reporting Notification