



En-----

Proc OH1600212

EDGEWOOD TERRACE MHP PWS

10/20/2011

Job  
Ma  
Sec



October 20 , 2011

RE: Coshocton County  
Edgewood Terrace MHP  
Community Water System  
PWS ID#OH1600212  
STU ID#OH1653600

Edgewood Terrace MHP  
c/o Ron Morningstar  
643 North High Street  
Hillsboro, OH 45133

**Notice of Violation**

Dear Mr. Morningstar:

Ohio EPA received your September Monthly Operating Reports submitted on October 8, 2011, for the Edgewood Terrace MHP public water system, but there were two inconsistencies with the free chlorine residual noted in the distribution system.


**September MOR, received October 8, 2011:**

Your public water system is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1) for failure to maintain a 0.2 mg/L free or 1 mg/L combined chlorine residual. There were 2 instances within the distribution system where this situation occurred for the month.

The free chlorine residuals have returned to compliance since the initial two days of non-compliance.

If you have any questions, please contact me at (740) 380-5229.

Sincerely,

  
Russell Flagg, REHS  
Environmental Specialist  
Division of Drinking and Ground Waters

RF/cb

cc: Central Office/DDAGW, Toni Buchanan  
Coshocton County Health Department  
Jamie Wilkins, SEDO

