OH3001212 BYESVILLE 7/2/2007

2195 Front Street
Logan, Ohio 43138

www.epa.state.oh.us

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 2, 2007

RE: GUERNSEY COUNTY
VILLAGE OF BYESVILLE
COMMUNITY PUBLIC WATER SYSTEM
PWS ID# 3001212

Village of Byesville
c/o Tom McVicker, Superintendent
59870 Vocational Road
Byesville, Ohio 43723

Dear Mr. McVicker:

This office received the 2006 Consumer Confidence Report (CCR) for the Village of Byesville public water system on June 28, 2007. As submitted, Byesville's water system is in violation of the OAC Rules 3745-96-01 through 04 for failure to comply with the CCR requirements. Specifically, the following deficiencies were noted:

1. The required turbidity language was not included: "Turbidity is a measure of the cloudiness of water and is an indication of the effectiveness of Byesville's filtration system. The turbidity limit set by the EPA is 0.3 in 95% of the daily samples and shall not exceed 1 NTU at any time. As reported, Byesville's highest recorded turbidity result for 2006 was 0.331 NTU and lowest monthly percentage of samples meeting the turbidity limits was 100%."

2. The definitions of the acronyms utilized within the report were not included.

Be sure to correct the aforementioned problems in your next CCR. The next report for calendar year 2007 must be sent to your customers no later than July 1, 2008. A copy of the CCR along with a Certification Form must be submitted to this office at the above address. Violations in future reports may result in further enforcement action.

If you have any questions or problems, please feel free to contact me at (740) 380-5207 or email me at sarah.wallace@epa.state.oh.us.

Sincerely,

Sarah Wallace

Sarah Wallace
Environmental Engineer
Division of Drinking and Ground Waters

SW/cb

cc: Guernsey County Health Department