



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

July 14, 2008

**RE: GUERNSEY COUNTY
VILLAGE OF BYESVILLE
COMMUNITY WATER SYSTEM
PWS ID# 3001212**

Village of Byesville
c/o Tom McVicker, Superintendent
59870 Vocational Road
Byesville, Ohio 43723

Dear Mr. McVicker:

We have reviewed your Fluoride Adjustment Operation Report covering the time period of June 2008 and have noted the following deficiencies:

- Fluoride was outside the required range of 0.8 - 1.3 mg/L for six (6) days during the month in violation of the Ohio Revised Code 6109.20 and Ohio Administrative Code 3745-82-03 (C).

Maintaining fluoride in the proper range is essential for optimum dental health. Please take prompt action to correct this operational water treatment plant problem. Also, please be aware, that under the newly revised OAC requirement, any future disruption of fluoride feed must be reported to Ohio EPA within 24 hours to prevent additional violations.

If you have any questions, please contact me at (740) 380-5207.

Sincerely,

Sarah Wallace
Environmental Engineer
Division of Drinking and Ground Waters

SW/cb

cc: Central Office/DDAGW
cc: Guernsey County Health Department
cc: **Jamie Wilkins, SEDO**

