



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 1, 2008

Re: **Harrison County  
Village of Scio  
Community  
OH3401312**

Village of Scio  
PO Box 307  
Scio, OH 43988

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of June 2008 and have noted the following deficiencies:

- The chlorine residual in the distribution system was not reported for 30 days during the month, which is a monitoring and reporting violation, as per OAC 3745-83-01.
- Plant tap chlorine residuals were not reported for three days during the month.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW  
cc: Harrison County Health Department  
cc: **Jamie Wilkins, SEDO**  
cc: Chris Edwards, P.O. Box 702, Gnadenhutten, OH 44629