



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 23, 2009

**Re: Harrison County
Village of Scio
Community
OH3401312**

Village of Scio
PO Box 307
Scio, OH 43988

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of September 2009 and have noted the following deficiencies:

- The chlorine residual in the distribution system was not reported for 4 days during the month, which is a monitoring and reporting violation, as per OAC 3745-83-01.

- Plant tap chlorine residuals were not reported for 4 days during the month.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Harrison County Health Department
cc: Jamie Wilkins, SEDO
cc: Chris Edwards, P.O. Box 702, Gnadenhutten, OH 44629