




E
F

OH3401503

HCWSD-UNIONVALE-KENWOOD PWS

2/28/2011



February 28, 2011

RE: **HARRISON COUNTY
HCWSD- UNIONVALE KENWOOD
COMMUNITY WATER SUPPLY
I.D. NO. 3401503**

HCWSD Unionvale Kenwood
Attn: Robert Sterling, County Engineer
100 West Market Street
Cadiz, OH 43907

We have reviewed your Monthly Operating Report covering the time period of January 2011 and have noted the following deficiencies:

- Chlorine residuals were not collected from the distribution system for two days during the month.
- Chlorine residuals were below the required levels on one day during the month.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Harrison County Health Department
cc: **Jamie Wilkins, SEDO**