



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

September 30, 2010

RE: **HARRISON COUNTY  
HCWSD UNIONVALE KENWOOD  
COMMUNITY WATER SUPPLY  
I.D. NO. 3401503**

HCWSD Unionvale Kenwood  
Attn: Robert Sterling, County Engineer  
100 West Market Street  
Cadiz, OH 43907


We have reviewed your Monthly Operating Report covering the time period of August 2010 and have noted the following deficiencies:

- Chlorine residuals were not collected for three days
- Total chlorine residuals, report sample results from days that routine bacteria samples are collected most of the time it would be 1 sample per month. The combined residual is the difference between the total and the free. Please review the attached direction for reporting.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,



Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW  
cc: Harrison County Health Department  
cc: **Jamie Wilkins, SEDO**