



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

October 23, 2009

RE: **HARRISON COUNTY  
HCWSD PIEDMONT  
COMMUNITY WATER SUPPLY  
I.D. NO. 3401212**

HCWSD Piedmont  
Attn: Robert Sterling, County Engineer  
100 West Market Street  
Cadiz, OH 43907

We have reviewed your Total Chlorine Residual Quarterly Operating Report covering the time period of July, August and September 2009 and have noted the following deficiencies:

- On the Total Chlorine Report 5114, report the total chlorine sample results taken on the day and at the same location you collect your routine total coliform samples only.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,



Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW  
cc: Harrison County Health Department  
cc: **Jamie Wilkins, SEDO**