



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

October 22, 2010

RE: **HARRISON COUNTY**
HCWSD- UNIONVALE KENWOOD
HCWSD- PIEDMONT
COMMUNITY WATER SUPPLY
I.D. NO. 3401503
I.D. NO. 3401212

HCWSD Unionvale Kenwood, Piedmont
Attn: Robert Sterling, County Engineer
100 West Market Street
Cadiz, OH 43907

We have reviewed your Monthly Operating Reports covering the time period of September 2010 and have noted the following deficiencies:

- From the Piedmont system, Chlorine residuals were not collected from the distribution system for thirty days during the month.
- Total Chlorine Residual Quarterly Operating Report for both systems. Total chlorine residuals, report sample results from days that routine bacteria samples are collected most of the time it would be 1 sample per month. The combined residual is the difference between the total and the free. Instructions for reporting data were provided in a previous letter.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office/DDAGW
cc: Harrison County Health Department
cc: **Jamie Wilkins, SEDO**