



2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

June 15, 2010

RE: **HARRISON COUNTY
BOWERSTON
COMMUNITY PUBLIC WATER SYSTEM
PWS ID#OH3400112
STU ID#3454932**

Village of Bowerston WTP
Attn: Jeremiah Warner
PO Box 2
Bowerston, OH 44695

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of April 2010 and have noted the following deficiencies:

- Chlorine levels were not analyzed in the distribution system as required on four days that water was produced.
- No iron and manganese results were submitted for the second, third or fourth weeks.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Harrison Health Department
cc: **Jamie Wilkins, SEDO**