




OH3400112

BOWERSTON VILLAGE PWS

8/31/2010



2195 Front Street  
Logan, Ohio 43138

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

August 31, 2010

RE:

**HARRISON COUNTY  
BOWERSTON  
COMMUNITY PUBLIC WATER SYSTEM  
PWS ID#OH3400112  
STU ID#3454932**

Village of Bowerston WTP  
Attn: Operator  
PO Box 2  
Bowerston, OH 44695

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of July 2010 and have noted the following deficiencies:

- Chlorine levels were not analyzed in the distribution system as required on seven days that water was produced.
- One manganese sample result was not reported for the fourth week.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith  
Environmental Specialist  
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW  
cc: Harrison Health Department  
cc: **Jamie Wilkins, SEDO**