



TELE: (740) 385-8501 FAX: (740) 385-6490
www.epa.state.oh.us

2195 Front Street
Logan, Ohio 43138

Ted Strickland, Governor
Lee Fisher, Lieutenant Governor
Chris Korleski, Director

August 2, 2010

RE: **HARRISON COUNTY
BOWERSTON
COMMUNITY PUBLIC WATER SYSTEM
PWS ID#OH3400112
STU ID#3454932**

Village of Bowerston WTP
Attn: Operator
PO Box 2
Bowerston, OH 44695

We have reviewed your Plant Distribution Monthly Operation Report covering the time period of June 2010 and have noted the following deficiencies:

- Chlorine levels were not analyzed in the distribution system as required on eight days that water was produced.

Please take prompt action to correct these reporting deficiencies in your next operational reports.

If you have any questions, please contact me at (740) 380-5275.

Sincerely,

Randy R. Smith
Environmental Specialist
Division of Drinking and Ground Waters

RRS/cb

cc: Central Office / DDAGW
cc: Harrison Health Department
cc: **Jamie Wilkins, SEDO**