



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

December 21, 2012

Robert Stewart
6455 Taylor Road
Blacklick, OH 43004

**Franklin County
Jefferson Water And Sewer District PWS
COMMUNITY PWS
PWS ID: OH2504012**

Dear Public Water System Owner:

The Public Water System serving JEFFERSON WATER AND SEWER DISTRICT PWS is in violation of the Ohio Administrative Code (OAC) 3745-82-03 (C)(1)(c), for failure to maintain fluoride between 0.8 – 1.3 mg/L at the plant tap for four or more days during the month. Specifically, there were eleven (11) days during the month of November 2012 in which fluoride was outside this range. No public notice is required for this violation. Please review your operations to determine the reason for the variability of the fluoride feed and advise this office as to what corrections will be made.

Should you have any questions, please do not hesitate to call me at (614) 728-3866 or email me at Scott.Kraner@epa.state.oh.us.

Sincerely,

Scott D. Kraner, P.E.
Environmental Engineer II
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

SK/ct 2504012(MI)NOV2012