




John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



October 29, 2012

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mary Ann Frey  
1249 County Road 140  
Sugarcreek, OH 44681

Tuscarawas County  
Cherry Ridge Waterworks, Ltd.  
COMMUNITY PWS  
PWS ID: OH7900303

Dear Public Water System Owner:

The Public Water System serving Cherry Ridge Waterworks, Ltd. is in violation of the Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1).

In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system.

According to the September 2012, Monthly Operating Report (MOR) Cherry Ridge Waterworks, Ltd. recorded ten samples in which the chlorine residual was below the required 0.2 mg/L free or 1.0 mg/L combined in the distribution system. This is the second consecutive month in which several of samples taken in the distribution have failed to meet the chlorine residual requirements of OAC 3745-83-01(C)(1). The August 2012 MOR for the Cherry Ridge Waterworks, Ltd. public water system also identified multiple days in which the chlorine residual was below required levels.

If you have any questions please call me at 740-380-5216.

Sincerely,

Taylor Carpenter  
Environmental Specialist II  
Ohio EPA Southeast District Office  
Division of Drinking Water

TC/cb

cc: Edward Wilson, Operator