



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

January 2, 2013

Mark Anthony
Owner
15111 State Route 664 South
Logan, OH 43138

Fairfield County
Hillview Mobile Village
COMMUNITY PWS
PWS ID: OH2302712

Dear Public Water System Owner:

The Public Water System serving HILLVIEW MOBILE VILLAGE is in violation of the Ohio Administrative Code (OAC) 3745-83-01 for:

Failure to maintain a minimum chlorine residual level of at least 0.2 mg/L free chlorine or 1.0 combined chlorine at representative points throughout the distribution system.

Please respond within 15 days from the date of this letter with a corrective action plan. Failure to provide and follow an action plan may result in an enforcement action being initiated.

If you have any questions please call your Ohio EPA representative at 614-728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec: CDO DDAGW AA (State Violation)

CO/cr 2302712(GS)DEC24