



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 4, 2013

RE: **NOTICE OF VIOLATION**
SUMMIT COUNTY
SEASONS REHAB AND CARE CENTER
COMMUNITY WATER SYSTEM
PWS ID # OH7704812

Meredith Flaherty
Seasons Rehab and Care Center
456 Seasons Road
Stow, OH 44224

CERTIFIED MAIL

Dear Ms. Flaherty:

This letter is notification that the Seasons Rehab and Care Center public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Seasons Rehab and Care Center PWS as reported on Monthly Operating Report (MOR) #5002 for the month of November 2012. Results reported on the form indicated seven (7) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual. In addition, please begin using eDWR so that the results are in a more legible format.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Kim Ethers, Ohio EPA, NEDO, DDAGW
Bill Roth, Operator of Record