



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 4, 2013

RE: **NOTICE OF VIOLATION**
COLUMBIANA COUNTY
PLEASANT VIEW NORTH RETIREMENT CENTER
COMMUNITY WATER SYSTEM
PWS ID # OH1502712

Ms. Liz Shutler
Pleasant View North
451 Valley Road
Salem, OH 44460

CERTIFIED MAIL

RE: NOTICE OF VIOLATION

Dear Ms. Shutler:

This letter is notification that the Pleasant View North Retirement Center public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Pleasant View North Retirement Center PWS as reported on Monthly Operating Report (MOR) #5002 for November 2012. Results reported on the form indicated sixteen (16) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within 30 days of the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,


J. Robert Henn

Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

ec: Kim Eppers, Ohio EPA, NEDO, DDAGW