



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

January 4, 2013

RE: SUMMIT COUNTY  
NON-COMMUNITY PUBLIC WATER SYSTEMS  
MANCHESTER LOCAL SCHOOLS  
**HIGH SCHOOL**  
PWS ID# OH7778012; STU ID# 7758959  
**MIDDLE SCHOOL**  
PWS ID# OH7762512; STU ID# 7758878  
**NOLLEY ELEM.**  
PWS ID# OH7778112; STU ID# 7758960

Mr. Sam Reynolds - Superintendent  
Manchester Local Schools  
6075 Manchester Road  
Akron, OH 44319

**CERTIFIED MAIL**

Dear Mr. Reynolds:

This letter is notification that the above referenced public water systems are in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to check the free chlorine once every day that water is available to the public from either the distribution or the entry point.

This violation of the OAC is based upon information submitted by the Manchester Local Schools as reported on Monthly Operating Report (MOR) #5002 for November 2012. Results reported on the form indicated multiple days where the minimum chlorine residual was not collected.

An evaluation/investigation should be conducted to determine why the samples were not collected and what corrective action is necessary. Please provide your findings to this writer within thirty days from the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

J. Robert Henn, Environmental Specialist  
Division of Drinking and Ground Waters

JRH/ams

Enclosures: Bacteria Sample Siting Plan

cc: Kim Etters, Ohio EPA, NEDO, DDAGW  
Ohio EPA, Central Office, DDAGW / OFAS  
Michael Stafford, Director of Services  
Philip Bevington, Operator of Record