



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director

January 4, 2013

RE: **NOTICE OF VIOLATION**
SUMMIT COUNTY
NIMISILA MHP
COMMUNITY WATER SYSTEM
PWS ID # OH7702912

Ms. Michelle Newton
1529 Brittain Road #7
Akron, OH 44310

CERTIFIED MAIL

Dear Ms. Newton:

This letter is notification that the Nimisila MHP public water system is in violation of Ohio Administrative Code (OAC) Rule 3745-83-01 for failure to maintain a minimum of 0.2 mg/L free chlorine residual measured at representative points throughout the distribution system.

This violation of the OAC is based upon information submitted by the Nimisila MHP PWS as reported on Monthly Operating Report (MOR) #5002 for November 2012. Results reported on the form indicated two (2) days where the minimum chlorine residual in the distribution system was less than 0.2 mg/L free chlorine residual.

An evaluation/investigation should be conducted to determine why the low residual occurred and what corrective action is necessary. Please provide your findings to this writer within thirty days from the date of this letter.

If you have any questions, please contact me directly at (330) 963-1248.

Respectfully,

A handwritten signature in black ink that reads "J. Robert Henn". The signature is written in a cursive style and includes a circled "R" as a monogram.

J. Robert Henn
Environmental Specialist
Division of Drinking and Ground Waters

JRH/ams

cc: Kim Eters, Ohio EPA, NEDO, DDAGW