



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

January 10, 2013

Mr. Ron Morningstar
Oakridge Estates LLC
643 North High Street
Hillsboro, Ohio 45133

Marion County
Oakridge Estates LLC
Community PWS
PWS ID: OH5100212

Dear Mr. Morningstar:

The Public Water System serving Oakridge Estates LLC is in violation of the Ohio Administrative Code (OAC) for failure to comply with the operational requirements of OAC 3745-83-01 during the month of November, 2012.

In violation of OAC 3745-83-01 (F)(2), the public water system failed to report the free or combined chlorine residual daily at the plant tap and distribution system. There were 21 days during the month in which the analysis was not performed.

If you have any questions, please contact me at (419) 373-3108.

Sincerely,

Janis D'Amico
Division of Drinking and Ground Waters

/cg

pc: DDAGW – NWDO

