



State of Ohio Environmental Protection Agency

**Southeast District Office**

2195 Front Street  
Logan, Ohio 43138

TELE: (740) 385-8501 FAX: (740) 385-6490  
www.epa.state.oh.us

Ted Strickland, Governor  
Lee Fisher, Lieutenant Governor  
Chris Korleski, Director

May 24, 2007

**Re:** Lawrence County  
Village of Coal Grove  
Water Treatment Plant  
Inspection  
Correspondence (IWW)

Mayor and Council  
Village of Coal Grove  
513 Carlton Davidson Lane  
Coal Grove, Ohio 45638

Dear Mayor and Council:

On April 11, 2007, I conducted a Compliance Evaluation Inspection (CEI) at the Village of Coal Grove's water treatment plant. The purpose of the inspection was to determine the Village's compliance with its National Pollutant Discharge Elimination System (NPDES) Permit. Kevin Markins was present for the Village of Coal Grove. A copy of my inspection report is attached.

As a result of my inspection, I have the following comments:

1. The outfalls in the NPDES Permit were inspected and no problems were found.
2. Ohio EPA is currently working on the renewal NPDES Permit for the discharges. The draft renewal NPDES Permit should be issued in the next couple of months. The Village should continue to follow the existing NPDES Permit until the renewal becomes effective.

In conclusion, the Village of Coal Grove's water treatment plant appeared to be in compliance with its NPDES Permit at the time of the inspection.

If you have any questions, feel free to contact me at (740) 380-5434.

Sincerely,

Stephen Wells  
District Representative  
Division of Surface Water

SW/dh

Enclosure

c: Kevin Markins, Village of Coal Grove

**NPDES**  
Compliance Inspection Report

**A. NATIONAL DATA SYSTEM CODING**

Permit No.	NPDES No.	Date	Inspection Type	Inspector	Facility Type
0IN00192*BD	OH0104558	April 11, 2007	C	S	2

**B. FACILITY DATA**

Name and Location of Facility Inspected	Entry Time	Permit Effective Date
Village of Coal Grove Water Treatment Plant 101 Riverside Drive Coal Grove, Ohio 45638	12:30 p.m.	June 1, 2002
	Exit Time	Permit Expiration Date
	1:30 p.m.	May 31, 2007

Name(s) and Title(s) of On-Site Representative(s)	Phone Number(s)
Kevin Markins, Operator	(740) 532-4769
Name, Address and Title of Responsible Official	Phone Number
Mayor and Council Village of Coal Grove 513 Carlton Davidson Lane Coal Grove, Ohio 45638	(740) 532-7447

**C. AREAS EVALUATED DURING INSPECTION**

<u>S</u> Permit	<u>S</u> Flow Measurement	<u>N/A</u> Pretreatment
<u>S</u> Records/Reports	<u>N</u> Laboratory	<u>N/A</u> Compliance Schedules
<u>S</u> Operations & Maintenance	<u>S</u> Effluent/Receiving Waters	<u>S</u> Self-Monitoring Program
<u>S</u> Facility Site Review	<u>N/A</u> Sludge Storage/Disposal	<u>--</u> Other
<u>N/A</u> Collection System		


(S = Satisfactory; M = Marginal; U = Unsatisfactory; N = Not Evaluated)

**D. SUMMARY OF FINDINGS/COMMENTS** (attach additional sheets if necessary)

See attached letter.

  
\_\_\_\_\_  
Stephen Wells, Inspector, Ohio EPA, Southeast District Office

5/24/07  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
Timothy M. Campbell, Reviewer, Ohio EPA, Southeast District Office

5/24/07  
\_\_\_\_\_  
Date