



**Environmental
Protection Agency**

FILE COPY

Ohio Governor
Ohio Lt. Governor
Ohio Director



NOTICE OF VIOLATION – ACTION REQUIRED

September 25, 2012

Sandra McCoy
Community Gardens MHP
6244 London-Groveport Road
Lot 69
Grove City, OH 43123

Franklin County
Community Gardens MHP
COMMUNITY PWS
PWS ID: OH2500512

Dear Ms. McCoy:

Community Gardens MHP is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for both iron and manganese during the month of August, 2012. The iron level was exceeded for three of five sampling events and manganese was exceeded in all of the five sampling events.

Violation of the secondary standards for iron and manganese does not require public notification but Community Gardens MHP must take immediate action to resolve this violation. Please review your operations to determine the reason for the exceedances and advise this office as to what corrections will be made within 10 days of the date of this letter. If you have any questions, please call me at 614-728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

ec/pc: John Kinder, Operator of Record, 961 Lakeshore Drive W. Hebron, OH 43025
Franklin County Health Department
IMS, DDAGW/CO
AA, DDAGW/CDO
CDO File

CO/ct 2500512(MI)AUG2012

Central District Office
50 West Town Street, Suite 700
P.O. Box 1049
Columbus, OH 43216-1049

614 | 728 3778
614 | 728 3898 (fax)
www.epa.ohio.gov