



Governor  
Lt. Governor  
Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

September 25, 2012

Greenlawn Mobile Home Service  
555 Greenlawn Avenue  
Columbus, OH 43223

Franklin County  
Enchanted Acres MHP  
COMMUNITY PWS  
PWS ID: OH2500712

Dear Owner:

Enchanted Acres Mobile Home Park is in violation of Ohio Revised Code Chapter 6109 as follows:

In violation of OAC 3745-82-02, the public water system has exceeded the secondary standard for both iron and manganese during the month of August, 2012. The iron and manganese levels were exceeded in all four sampling events.

Violation of the secondary standards for iron and manganese does not require public notification but Enchanted Acres MHP must take immediate action to resolve this violation. Please review your operations to determine the reason for the exceedances and advise this office as to what corrections will be made within 10 days of the date of this letter. If you have any questions, please call me at 614-728-3864.

Sincerely,

Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

ec/pc: Joe Hickman, 236 Granger St., Granville, OH 43023  
Franklin County Health Department  
IMS, DDAGW, CO  
AA, DDAGW, CDO  
CDO File

CO/ci 2500712(MI)AUG2012