



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



January 18, 2013

NOTICE OF VIOLATION – ACTION REQUIRED

Ms. Rebecca Hammer
7-Eleven Store #36177
1722 Routh Street, Suite 1000
Dallas, Texas 75205

Richland County
7-Eleven Store # 36177
Transient Non-Community PWS
PWS ID: OH7041912
PWS ID: 7057776

Dear Ms. Hammer:

The Public Water System serving 7-Eleven Store # 36177 is in violation of the Ohio Administrative Code (OAC) for failing to comply with the operational requirements of OAC 3745-83-01 during the month of December, 2012.

In violation of OAC 3745-83-01(F)(2), the public water system failed to report both the free and combined chlorine residuals each day water was served. There were twenty-nine (29) days during the month in which no analysis was reported.

If you have any questions regarding this letter, please contact me at 419-373-3102 or via email at kimberly.burnham@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, consisting of several overlapping loops and a long horizontal stroke extending to the right.

Kimberly K. Burnham, R.S.
Division of Drinking and Ground Waters

/llr

pc: Richland County Health Department
McGhee's Technical Water Service, Inc.
File: DDAGW – NWDO

