





John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director

Re: Sandusky County  
Sycamore Hills Golf Club  
Transient Non-Community PWS  
PWS ID# OH7256412  
STU ID# 7258043

January 22, 2013

Mr. Douglas Michael  
3278 West Hayes Avenue  
Fremont, Ohio 43420

Dear Mr. Michael:

On November 15, 2012, the Ohio Environmental Protection Agency (Ohio EPA), Division of Drinking and Ground Waters (DDAGW), received a response from you regarding the requirements listed in Ohio EPA's October 5, 2011, sanitary survey report of the Sycamore Hills Golf Club public water system. Your response indicates that the new well cap was replaced and the animal burrow hole was filled as required.

Thank you for your prompt attention to these issues.

If you have any questions regarding this letter, or any other matter involving your water system, please contact me at 419-373-3108 or via email at [Janis.Damico@epa.state.oh.us](mailto:Janis.Damico@epa.state.oh.us).

Sincerely,

A handwritten signature in cursive script that reads "Janis D'Amico".

Janis D'Amico  
Environmental Specialist 2  
Division of Drinking and Ground Waters

/l/r

pc: Sandusky County Health Department  
Andy Barienbrock, DDAGW, CO  
DDAGW – NWDO File

ec: Janis D'Amico, DDAGW, NWDO

