



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



January 23, 2013

**NOTICE OF VIOLATION – ACTION REQUIRED**

Mr. Hardev Sarao  
Dashmesh Truck Stop, LLC  
4541 Route 20  
Gibsonburg, Ohio 43431

Sandusky County  
Dashmesh Truck Stop, LLC  
Transient Non-Community PWS  
PWS ID: OH7257212

Dear Mr. Sarao:

This letter is notification that the Dashmesh Truckstop has not complied with requirements issued during this Agency's last survey performed on November 1, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated November 21, 2012, to respond in writing no later than 30 days, with time frames for compliance with the following requirements:

1. According OAC Rule 3745-9-05 (T), "A vent shall be provided on all well caps and seals...A well vent shall be self-draining, screened with a non-corroding mesh screen of fifteen to thirty mesh, pointed downward at or above the top of the casing or pitless unit. A vent shall terminate not less than twelve inches above ground surface."

**The well does not have an appropriate vent on the cap. Install a cap that meets the specifications identified in OAC 3745-9-05 (T) and includes a screened vent.**

2. OAC Rule 3745-95-05(A)(1) states in part that an approved air gap separation shall be installed where a public water system may be contaminated with substances that could cause a sever health hazard. The drain line from the softener was not isolated from the waste water plumbing.

**Maintain the terminal end of the drain lines from the treatment equipment suspended at least two (2) pipe diameters above the flood rim level of the floor drain.**

3. Records are not maintained by the certified operator in compliance with the requirements of OAC Rule 3745-7-09. Specific examples include the failure to report the date and time of arrival and departure of the operator of record as it relates to work associated with the public water system, performance of preventive maintenance and repairs, and identification of the person making the entry.

Mr. Hardev Sarao  
January 23, 2013  
Page 2


**The recordkeeping shall be reviewed and modified so as to fully conform with the requirements of OAC Rule 3745-7-09.**

**Respond in writing upon receipt of this letter with time frames for compliance with the above requirements.**

Scott Green provided a copy of a completed Sample Siting Plan on November 26, 2012. This satisfied Requirement #2 of the sanitary survey letter.

If you have any questions, please contact me at (419) 373-3108 or via e-mail at [janis.damico@epa.ohio.gov](mailto:janis.damico@epa.ohio.gov).

Sincerely,



Janis D'Amico  
Division of Drinking and Ground Waters

/llr

pc: Sandusky County Health Department  
DDAGW, Operations CO  
DDAGW - NWDO File