



John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



## NOTICE OF VIOLATION – ACTION REQUIRED

January 23, 2013

Ms. Tonja Coleman  
Tractor Supply Company-Fremont  
200 Powell Place  
Brentwood, Tennessee 37027

Sandusky County  
Tractor Supply Company-Fremont  
Transient Non-Community PWS  
PWS ID: OH7256512

Dear Ms. Coleman:

This letter is notification that the Tractor Supply Company - Fremont has not complied with requirements issued during this Agency's last survey performed on October 2, 2012, in violation of rule 3745-81-60 of the Ohio Administrative Code. The PWS was notified in correspondence dated October 25, 2012 to respond in writing no later than 30 days, with time frames for compliance with the following requirements:

1. Mr. Deuschle indicated that the Tractor Supply Company-Fremont has approximately 300 customers each weekday and approximately 450 customers on weekend days. Additionally, the store has five (5) part-time and seven (7) full-time employees. According to OAC Rule 3745-7-03, Class A Operator Certification is required for this system based on the most recently reported population numbers.

**Your system is not operating under the supervision of an operator of record (ORC). A certified Class A operator must be placed in responsible charge of your system as the ORC.**

Contact Andy Barienbrock at (614) 728-1216 for information regarding obtaining an ORC for your system.

2. According to OAC Rule 3745-9-05 (T), "A vent shall be provided on all well caps and seals...A well vent shall be self-draining, screened with a non-corroding mesh screen of fifteen to thirty mesh, pointed downward at or above the top of the casing or pitless unit. A vent shall terminate not less than twelve inches above ground surface."

Ms. Tonja Coleman  
January 23, 2013  
Page 2

**The well does not have an appropriate vent on the cap. Install a cap that meets the specifications identified in OAC 3745-9-05 (T) and includes a screened vent.**


3. A total coliform sample siting plan was not on file in accordance with OAC 3745-81-21(A). A template for a total coliform sample siting plan has been included with this survey letter. The template for the plan should be completed and filed. The plan should be maintained and updated as required.

**Complete the template of the sample siting plan provided to you and return a copy to my attention.**

**Respond in writing upon receipt of this letter with time frames for compliance with the above requirements.**

If you have any questions, please contact me at (419) 373-3108 or via e-mail at [janis.damico@epa.ohio.gov](mailto:janis.damico@epa.ohio.gov).

Sincerely,



Janis D'Amico  
Division of Drinking and Ground Waters

/cg

pc: Sandusky County Health Department  
DDAGW, Operations CO  
DDAGW – NWDO File