


John R. Kasich, Governor  
Mary Taylor, Lt. Governor  
Scott J. Nally, Director



**NOTICE OF VIOLATION – ACTION REQUIRED**

January 16, 2013

Suzanne Mates  
Owner  
4330 River Landings Court  
Hilliard, OH 43026-7823

Franklin County  
Community Gardens MHP  
COMMUNITY PWS  
PWS ID: OH2500512

Dear Ms. Mates:

The Public Water System serving COMMUNITY GARDENS MHP is in violation of the Ohio Administrative Code (OAC) 3745-82-02 as follows:

- *In accordance with OAC 3745-82-02, the secondary maximum contaminant level (SMCL) for iron is 0.3 mg/L. In December 2012, the SMCL for iron was exceeded in three of the four weeks in which iron levels are reported. Each exceedance is a violation of Ohio Administrative Code 3745-82-02.*

On-site manganese testing is strongly recommended to allow for immediate identification and correction of operational issues. Compliance monitoring for manganese may be either; weekly by a state certified laboratory or weekly with an in-house test kit and one split sample monthly by a certified lab. Please refer to 3745-83-01(F)(6)(c) for quality control requirements and contact me if in-house testing is desired.

Within 14 days of the date of this letter, please provide an explanation on what has been done to correct these violations to prevent this from happening in the future. If you have any questions, please contact me at carolyn.o'neal@epa.state.oh.us or at (614) 728-3864.

Sincerely,

Carolyn O'Neal  
Environmental Specialist III  
Division of Drinking and Ground Waters  
Central District Office

c: Manufactured Housing Commission  
Franklin County Health Department  
ec: CDO DDAGW AA (State Violation)

CO/ct 2500512(MI)DEC2012