


John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

January 16, 2013

Mark Anthony
Owner
15111 State Route 664 South
Logan, OH 43138

Fairfield County
Hillview Mobile Village
COMMUNITY PWS
PWS ID: OH2302712

Dear Mr. Anthony:

The Public Water System serving HILLVIEW MOBILE VILLAGE is in violation of the Ohio Administrative Code (OAC) 3745-83-01 for the following items:

1. *In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. During the month of December, 2012, Hillview Mobile Village failed to maintain a minimum chlorine residual level in the distribution system for 11 days.*
2. *OAC Rule 3745-83-01(F)(2) requires the public water system owner to monitor both the free or combined chlorine residuals at least once every day at the plant tap and at a representative point or points out in the distribution system. During the month of December, 2012, Hillview Mobile Village failed to report daily plant tap free or combined chlorine residual levels.*

Please respond within 15 days of the date of this letter with a corrective action. Failure to provide and follow an action plan may result in further enforcement action. If you have any questions, please contact me at carolyn.o'neal@epa.state.oh.us or at (614) 728-3864.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: Manufactured Housing Commission
Fairfield County Health Department
ec: CDO DDAGW AA (State Violation)

CO/cr 2382712(MI)DEC2012