



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Scott J. Nally, Director



NOTICE OF VIOLATION – ACTION REQUIRED

January 16, 2013

Gayle Scott
Scottco Investment Companies
P. O. Box 4205
Newark, OH 43058

**Franklin County
Pleasant Acres MHP
COMMUNITY PWS
PWS ID: OH2502912**

Dear Mr. Scott:

The Public Water System serving PLEASANT ACRES MHP is in violation of the Ohio Administrative Code (OAC) 3745-83-01 and OAC 3745-82-02.

1. In accordance with Ohio Administrative Code (OAC) Rule 3745-83-01(C)(1), community water systems are required to maintain a minimum chlorine residual of at least 0.2 mg/L free or 1.0 mg/L combined chlorine throughout the distribution system. Chlorine residual levels are measured daily. For a total of 11 days throughout the months of September, October, November and December, 2012, chlorine residual levels were reported to be below the minimum required levels.
2. In accordance with OAC 3745-82-02, the secondary maximum contaminant level (SMCL) for iron is 0.3 mg/L. The monthly operating report (MOR) submitted for December, 2012, shows an iron level above the secondary MCL at 0.64 mg/L.

Within 15 days of the date of this letter, please provide the corrective actions taken to prevent these violations from occurring in the future. If you have any questions, please contact me at (614) 728-3864 or at carolyn.o'neal@epa.state.oh.us.

Sincerely,

Carolyn O'Neal
Environmental Specialist III
Division of Drinking and Ground Waters
Central District Office

c: Manufactured Housing Commission
Franklin County Health Department
ec: CDO DDAGW AA (State Violation)

CO/cf 2502912(M)DEC2012